



SCALANCE X204IRT, managed IE IRT switch, 4x 10/100 Mbps RJ45 ports, error signaling contact with set button, redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-PLUG optional

<b>product type designation</b>	<b>SCALANCE X204IRT</b>
<b>transfer rate</b>	
transfer rate	10 Mbit/s, 100 Mbit/s
<b>interfaces / for communication / integrated</b>	
number of electrical connections • for network components or terminal equipment	4
<b>interfaces / other</b>	
number of electrical connections • for signaling contact • for power supply	1 1
type of electrical connection • for signaling contact • for power supply	2-pole terminal block 4-pole terminal block
design of the removable storage • C-PLUG	Yes
<b>signal inputs/outputs</b>	
operating voltage / of the signaling contacts • at DC / rated value	24 V
operational current / of the signaling contacts • at DC / maximum	0.1 A
<b>supply voltage, current consumption, power loss</b>	
<b>type of voltage / 1 / of the supply voltage</b> • supply voltage / 1 / rated value • power loss [W] / 1 / rated value • supply voltage / 1 / rated value • consumed current / 1 / maximum • type of electrical connection / 1 / for power supply • product component / 1 / fusing at power supply input • fuse protection type / 1 / at input for supply voltage	DC 24 V 4.8 W 18 ... 32 V 0.14 A 4-pole terminal block Yes 0.6 A / 60 V
<b>ambient conditions</b>	
ambient temperature • during operation • during storage • during transport	-40 ... +70 °C -40 ... +85 °C -40 ... +85 °C
relative humidity • at 25 °C / without condensation / during operation / maximum	95 %
protection class IP	IP30
<b>design, dimensions and weights</b>	
design	compact

width	60 mm
height	125 mm
depth	124 mm
net weight	0.78 kg
fastening method	
• 35 mm top hat DIN rail mounting	Yes
• wall mounting	Yes
• S7-300 rail mounting	Yes
• S7-1500 rail mounting	No

**product features, product functions, product components / general**

cascading in the case of a redundant ring / at reconfiguration time of <math>\sim 0.3\text{ s}</math>	50
cascading in cases of star topology	any (depending only on signal propagation time)

**product functions / management, configuration, engineering**

product function	
• CLI	Yes
• web-based management	Yes
• MIB support	Yes
• TRAPs via email	Yes
• configuration with STEP 7	Yes
• port mirroring	No
• multiport mirroring	No
• with IRT / PROFINET IO switch	Yes
• PROFINET IO diagnosis	Yes
PROFINET conformity class	C
network load class / according to PROFINET	2
product function / switch-managed	Yes
protocol / is supported	
• Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• BOOTP	No
• DCP	Yes
• LLDP	Yes
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
identification & maintenance function	
• I&M0 - device-specific information	Yes
• I&M1 – higher level designation/location designation	Yes

**product functions / diagnostics**

product function	
• port diagnostics	Yes
• statistics Packet Size	Yes
• statistics packet type	Yes
• error statistics	Yes

**product functions / DHCP**

product function	
• DHCP client	Yes

**product functions / redundancy**

product function	
• ring redundancy	Yes
• High Speed Redundancy Protocol (HRP)	Yes
• high speed redundancy protocol (HRP) with redundancy manager	Yes
• high speed redundancy protocol (HRP) with standby redundancy	Yes
protocol / is supported / Media Redundancy Protocol (MRP)	Yes
product function	
• media redundancy protocol (MRP) with redundancy manager	Yes

<ul style="list-style-type: none"> <li>• Parallel Redundancy Protocol (PRP)/operation in the PRP-network</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA)</li> </ul>	No
<ul style="list-style-type: none"> <li>• passive listening</li> </ul>	Yes
<b>product functions / security</b>	
protocol / is supported	
<ul style="list-style-type: none"> <li>• SSH</li> </ul>	Yes
<b>product functions / time</b>	
product function	
<ul style="list-style-type: none"> <li>• SICLOCK support</li> </ul>	Yes
protocol / is supported	
<ul style="list-style-type: none"> <li>• NTP</li> <li>• SNTP</li> </ul>	No Yes
<b>standards, specifications, approvals</b>	
standard	
<ul style="list-style-type: none"> <li>• for FM</li> </ul>	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
<ul style="list-style-type: none"> <li>• for safety / from CSA and UL</li> </ul>	UL 60950-1, CSA C22.2 No. 60950-1
<ul style="list-style-type: none"> <li>• for emitted interference</li> </ul>	EN 61000-6-4:2001 (Class A)
<ul style="list-style-type: none"> <li>• for interference immunity</li> </ul>	EN 61000-6-2
MTBF	80.58 y
reference code	
<ul style="list-style-type: none"> <li>• according to IEC 81346-2</li> <li>• according to IEC 81346-2:2019</li> </ul>	KF KFE
<b>standards, specifications, approvals / CE</b>	
certificate of suitability / CE marking	Yes
certificate of suitability / RoHS conformity	Yes; EN 50581
<b>standards, specifications, approvals / hazardous environments</b>	
standard / for hazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
<ul style="list-style-type: none"> <li>• from CSA and UL</li> </ul>	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
certificate of suitability	
<ul style="list-style-type: none"> <li>• ATEX</li> </ul>	Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X
<ul style="list-style-type: none"> <li>• IECEx</li> </ul>	Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X
<ul style="list-style-type: none"> <li>• CCC / for hazardous zone according to GB standard</li> </ul>	Yes
<b>standards, specifications, approvals / other</b>	
certificate of suitability	EN 61000-6-4:2001
<ul style="list-style-type: none"> <li>• C-Tick</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• KC approval</li> </ul>	Yes
<ul style="list-style-type: none"> <li>• railway application in accordance with EN 50155</li> </ul>	No
<ul style="list-style-type: none"> <li>• railway application in accordance with EN 50124-1</li> </ul>	No
<ul style="list-style-type: none"> <li>• cULus approval</li> </ul>	UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480
<b>standards, specifications, approvals / marine classification</b>	
Marine classification association	
<ul style="list-style-type: none"> <li>• American Bureau of Shipping Europe Ltd. (ABS)</li> <li>• French marine classification society (BV)</li> <li>• Det Norske Veritas (DNV)</li> <li>• Germanische Lloyd (GL)</li> <li>• DNV GL</li> <li>• Lloyds Register of Shipping (LRS)</li> <li>• Nippon Kaiji Kyokai (NK)</li> <li>• Polski Rejestr Statkow (PRS)</li> <li>• Royal Institution of Naval Architects (RINA)</li> </ul>	Yes Yes No No Yes Yes Yes Yes Yes
<b>accessories</b>	
product extension / optional / C-PLUG	Yes
<b>further information / internet-Links</b>	
Internet-Link	

- to web page: selection aid TIA Selection Tool
- to website: Industrial communication
- to website: Industry Mall
- to website: Information and Download Center
- to website: Image database
- to website: CAX-Download-Manager
- to website: Industry Online Support

- <http://www.siemens.com/tia-selection-tool>
- <http://www.siemens.com/simatic-net>
- <https://mall.industry.siemens.com>
- <http://www.siemens.com/industry/infocenter>
- <http://automation.siemens.com/bilddb>
- <http://www.siemens.com/cax>
- <https://support.industry.siemens.com>

## security information

security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action (e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit <http://www.siemens.com/industrialsecurity>. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit <http://support.automation.siemens.com>. (V3.4)

last modified:

12/14/2022 