SIEMENS

Data sheet 5SV5312-6



Residual current operated circuit breaker, 2-pole, Type A, In: 25A, 30mA, Un AC: 230V Residential

Model	
product brand name	SENTRON
product designation	RCCB
design of the product	Instantaneous
General technical data	
number of poles	2
size of installation devices according to DIN 43880	1
mechanical service life (operating cycles) typical	3 000
short-circuit current of series fuse maximum permissible	63 A
short-circuit current rating	6 kA
switching function short-term delayed	No
overvoltage category	III
Supply voltage	
supply voltage for testing equipment minimum	195 V
value range of the supply voltage frequency	50 Hz
value range of the operating frequency	50 Hz
value range of the supply voltage at AC	230/400 V
Protection class	
protection class IP	IP20, if the distribution board is installed, with connected conductors
Switching capacity	
switching capacity current	
 according to IEC 61008-1 rated value 	0.5 kA
Dissipation	
power loss [W]	
 for rated value of the current at AC in hot operating state per pole 	2.6 W
• maximum	5.2 W
Product details	
product feature silicon-free	Yes
product extension installable supplementary devices	No
Connections	
connectable conductor cross-section solid	
• minimum	0.75 mm²
• maximum	35 mm²
connectable conductor cross-section stranded	
• minimum	0.75 mm²
• maximum	35 mm²
tightening torque with screw-type terminals	
• minimum	2.5 N·m
maximum	3 N⋅m

position of power supply cord		top or bott	om		
Mechanical Design					
height		90 mm			
width		36 mm			
depth		70 mm			
installation depth		70 mm			
number of modular width units		2			
fastening method		DIN rail (F	REG)		
mounting position		any			
grid spacing		60 mm			
net weight		192 g			
Environmental conditions					
ambient temperature during operation					
• minimum		-5 °C			
maximum		45 °C			
ambient temperature during storage minimum		-40 °C			
number of test cycles for environmental testing according to IEC 60068-2-30		28			
General Product Approval	other			Dangerous Good	Environment
Confirmation	Miscellaneo	<u>us</u>	Confirmation	Transport Information	Environmental Confirmations

Further information

Siemens has decided to exit the Russian market (see here).

 $\underline{https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business}$

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SV5312-6

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SV5312-6

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SV5312-6

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications

last modified:	3/21/2023