

Data sheet for SINAMICS G120P Cabinet

MLFB-Ordering data: 6SL3710-1PE36-6AA0-Z ** K74+K83+K96+L26+L45+M06+M54

Client order no.:

Order no.: Offer no.:

Remarks:

Item no.:

Consignment no.:

Project:


Converter losses to IEC61800-9-2*

Efficiency class

IE2

Comparison with the reference converter (90% / 100%)

44.6 %



The percentage values show the losses in relation to the rated apparent power of the converter.

The diagram shows the losses for the points (as per standard IEC61800-9-2) of the relative torque generating current (I) over the relative motor stator frequency(f). The values are valid for the basic version of the converter including line choke without options/components.

Rated data	
Input	
Supply frequency	4763 Hz
Supply voltage	400 V ±10%
Rated input current	668.0 A
Max. current	881 A
Pulse number	6
Energy recovery capability	No (2Q)
Output:	
Output voltage	400 V
Rated power (LO) in kW	355 kW
Rated power (HO) in kW	250 kW
Rated output current	655.0 A
Rated output current (LO)	640 A
Rated output current (HO)	491 A
Output current Max	864 A
Pulse frequency (nominal)	2.00 kHz
Basic data:	
Absolute power loss in stand-by	168 W
Sound pressure level L _{pA} (1 m)	69 dB
Conductor cross section, max. (IEC)	4 x 240 mm²
Degree of protection	IP54
Installation envelope dimensions (H x W x	2500 mm x 1200 mm x 600 mm
Weight approx.	500 kg
Frame size	FSHX
Design	Α
Color, paint shade	RAL7035
Compliance with standards	CE, RCM, EAC
Environmental conditions	
Installation altitude	1000 m
Coolant	Air

Special design		
K74	Supply of Cabinet internal AC 230 V auxiliary power	
K83	Stopp-Category 0 (STO)	
K96	Control Unit CU230P-2 PROFINET / EtherNet/IP	
L26	Main switch including fuses	
L45	EMERGENCY OFF pushbutton, mounted in the cabinet door	
M06	Base 100 mm high	
M54	IP54 degree of protection	

*calculated values

0.60 m³/s 0 °C - +40 °C

Coolant requirement, air

Ambient temperature

^{**}EMC shield rail with PE rail and crane transport aid included in the standard scope of delivery