Data sheet for three-phase Squirrel-Cage-Motors SIMOTICS



Motor type: 1AV3133C SIMOTICS GP - 132 M - IM B3 - 6p Offer no. Client order no. Item-No Order no. Consignment no. Project Remarks Safe Area Electrical data -/η 3) U Δ/Υ f Р Р ī М $cos\phi^{3)}$ I_A/I_N M_A/M_N M_K/M_N IE-CL n [V] [Hz] [kW] [hp] [A] [1/min] [Nm] 4/4 3/4 T_I/T_N T_B/T_N 2/4 4/4 3/4 2/4 I_I/I_N **DOL duty (S1)** - 155(F) to 130(B) 230 Δ 50 5.50 22.00 975 54.0 88.0 88.3 87.2 0.72 0.64 0.51 6.8 2.7 3.4 IE3 400 5.50 -/-12.50 0.51 50 975 54.0 88.0 88.3 87.2 0.72 0.64 6.8 2.7 3.4 IE3 Υ 60 6.30 -/-1175 89.5 89.7 88.6 0.66 0.53 7.1 3.5 460 12.10 51.0 0.73 2.3 IE2 Υ IE3 60 5.50 -1-1180 44.5 91.0 90.8 89.2 0.69 0.61 0.48 7.8 3.0 4.0 460 11.00 IM B3 / IM 1001 UKCA IEC/EN 60034 IEC, DIN, ISO, VDE, EN FS 132 M Environmental conditions: -20 °C - +40 °C / 1000 m Locked rotor time (hot / cold): 19.9 s | 27 s Mechanical data Sound level (SPL / SWL) at 50Hz|60Hz 63 / 75 dB(A) 2) 3) 67 / 79 dB(A) 2) 3) Vibration severity grade Α Moment of inertia 0.0500 kg m² Thermal class F Bearing DE | NDE 6208 2Z C3 6208 2Z C3 Duty type S1 bearing lifetime Direction of rotation bidirectional $L_{10mh}\,F_{Rad\,\,min}$ for coupling operation $50|60Hz^{\,1)}$ 40000 h 32000 h Frame material aluminum Regreasing device Without Net weight of the motor (IM B3) 58 kg Coating (paint finish) Standard paint finish C2 Grease nipple Preloaded bearing DE RAL7030 Type of bearing Color, paint shade Condensate drainage holes Without Motor protection (B) 3 PTC thermistors - for tripping (2 terminals) IC416 - separately ventilated, surface cooled External earthing terminal With Method of cooling Terminal box Terminal box position top Max. cross-sectional area 6 mm^2 Material of terminal box Aluminium Cable diameter from ... to ... 11 mm - 21 mm Type of terminal box TB1 H00 2xM32x1,5-1xM16x1,5 Cable entry Contact screw thread Μ4 Cable gland 3 plugs 1) L_{10mh} according to DIN ISO 281 10/2010 3) Value is valid only for DOL operation with motor design IC411 IA/IN = locked rotor current / current nominal M_A/M_N = locked rotor torque / torque nominal 2) at rated power / at full load M_K/M_N = break down torque / nominal torque Transmittal, reproduction, dissemination and/or editing of this document as well as utilization of its contents and communication thereof to others without express authorization are prohibited. Offenders will be held liable for payment of damages. All rights created by patent grant or registration of a utility model or design patent are reserved. Responsible department Technical reference Created by Approved by Technical data are subject to change! There may be discrepancies between calculated and rating plate IN LVM SPC Created automatically Document type Document status Released Technical data sheet **SIEMENS** Document number

TDS-240509-123132

Creation date

2024-05-09

Language

Page

Revision

Branding	disc	laimer	applies

© Innomotics 2024

Restricted

1LE1043-1CC32-2AB4-Z

F70+G03+H04

Data sheet for three-phase Squirrel-Cage-Motors SIMOTICS

Mounting of separately driven fan

Special design

F70



Motor type : 1AV3133C SIMOTICS GP - 132 M - IM B3 - 6p

G03	Mounting of rotary p	ulse encoder HOG 86E, 10	024 I							
Transmittal r	reproduction, dissemination an	d/or editing of this document as wel	ll as utilization of its contents and	communication thereof to others	without ex	press authoriza	tion are prohibited. Offenders w	vill be held liable	for payment of	
	and the second s			egistration of a utility model or des			p. zzcar onenders v	22214 114510	F=Jene of	
Pasnansible d	anartment	Technical reference	Created by	Approved by	Technica	al data are subi	ect to change! There may be	Link docum	onts	
Responsible de IN LVM	epartment				Il data are subject to change! There may be ncies between calculated and rating plate Document status		Link documents			
		Document type								
SIE		1			Released					
	MENS	Document title				Document number				
		1LE1043-1CC32-2AB4-Z				TDS-240	509-123132			
Restricted						Revision	Creation date	Language Page		
© Innomo	tics 2024					AA	2024-05-09	en	2/2	

H04

External grounding at housing