LV431570

CT module and voltage output - 250 A - 4 poles



| lai |
|-----|

| Range of product | INS250 INV100250 NSX100250 | |
|---------------------------|---|---|
| Range | Compact | , |
| Device short name | CT module and voltage output | |
| Product or component type | Current transformer | |
| Device application | Control | |
| Range compatibility | Compact INS circuit breaker Compact INV circuit breaker Compact NSX circuit breaker | ; |
| Poles description | 4P | |
| Network type | AC | |
| [In] rated current | 250 A 1.1 VA | |
| | | |

Complementary

| [Ue] rated operational voltage | 530 V | |
|--------------------------------|-------------------------------------|--|
| Network frequency | 50/60 Hz | |
| Current transformer ratio | 250/5 A | |
| Auxiliary connection terminal | Cable connector 2.5 mm ² | |

Environment

| Electrical shock protection class | Class II |
|-----------------------------------|------------------------------|
| IP degree of protection | IP40 conforming to IEC 60529 |
| IK degree of protection | IK04 conforming to IEC 62262 |

Offer Sustainability

| Compliant EU RoHS Declaration | |
|--|--------------------------------|
| Yes | |
| Yes | |
| China RoHS declaration Product out of China RoHS scope. Substance declaration for your information | |
| | Yes Yes China RoHS declaration |

| WEEE | The product must be disposed on European Union markets following specific waste collection and never end up in rubbish bins |
|----------------------|---|
| Contractual warranty | |
| Warranty | 18 months |