# **SIEMENS**

Product data sheet 3TK2828-2BB40



SIRIUS SAFETY RELAY WITH RELAY RELEASE CIRCUITS (RC),

DC 24V, 45.0MM, SPRING-LOADED TERMINAL,

RC INSTANT.: 2NO,

RC DELAYED: 2NO 0.5...30S, MC: 1NC,

AUTOSTART, BASIC DEVICE, MAX. ACHIEVABLE SIL: 3/2, PL: E/D

General technical details:		
product brand name		SIRIUS
product designation		safety relays
Design of the product		for EMERGENCY-STOP units
protection class IP / of the housing		IP20
Protection class IP / of the terminal		IP20
Protection against electrical shock		finger-safe
Insulation voltage / rated value	V	300
Ambient temperature		
during storage	°C	-40 +80
during operating	°C	-25 +60
Air pressure		
according to SN 31205	kPa	90 106
Relative humidity		
during operating phase	%	10 95
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against vibration / according to IEC 60068-2-6		5 500 Hz: 0,075 mm
Resistance against shock		8g / 10 ms
Impulse voltage resistance / rated value	V	4,000
EMC emitted interference		EN 60947-5-1

Installation environment relating to EMC		This product is suitable for Class A environments only. It can cause undesired radio-frequency interference in
		residential environments. If this is the case, the user must take appropriate measures.
Item designation		
<ul> <li>according to DIN 40719 extendable after IEC 204-2 / according to IEC 750</li> </ul>		КТ
according to DIN EN 61346-2		F
Number of sensor inputs		
• 1-channel or 2-channel		1
Design of the cascading		none
Type of the safety-related wiring / of the inputs		single-channel and two-channel
Product feature / transverse contact-secure		Yes
Safety Integrity Level (SIL)		
according to IEC 61508		SIL3
for delayed release circuit / according to IEC 61508		SIL2
SIL claim limit (for a subsystem) / according to EN 62061		3
Performance Level (PL)		
according to ISO 13849-1		е
• for delayed release circuit / according to ISO 13849-1		d
Category / according to EN 954-1		4
Category / according to ISO 13849-1		4
Hardware fault tolerance / according to IEC 61508		1
Safety device type / according to IEC 61508-2		Туре А
Probability of dangerous failure per hour (PFHD) / with high demand rate / according to EN 62061	1/h	0.27E-8
Average probability of failure on demand (PFDavg) / with low demand rate / according to IEC 61508	1/y	0.24E-5
T1 value / for proof test interval or service life / according to IEC 61508	а	20
Number of outputs / as contact-affected switching element		
• as NC contact / for reporting function / instantaneous switching		1
as NO contact / safety-related / instantaneous switching		2
as NO contact / safety-related / delayed switching		2
Number of outputs / as contact-less semiconductor switching element		
safety-related		
delayed switching		0
• non-delayed		0
for reporting function		
delayed switching		0
• non-delayed		0

General technical details:		
Design of the input		
cascading-input/functional switching		No
feedback input		Yes
• start input		Yes
Design of the electrical connection / jumper socket		Yes
Operating cycles / maximum	1/h	1,000
Switching capacity current		
of NO contacts of relay outputs		
• at DC-13		
• at 24 V	Α	5
• at 115 V	Α	0.2
• at 230 V	Α	0.1
• at AC-15		
• at 115 V	Α	5
• at 230 V	Α	5
of NC contacts of relay outputs		
• at DC-13		
• at 24 V	Α	5
• at 115 V	Α	0.2
• at 230 V	Α	0.1
• at AC-15		
• at 115 V	Α	5
• at 230 V	Α	5
Thermal current / of the contact-affected switching element / maximum	А	5
Electrical operating cycles as operating time / typical		100,000
Mechanical operating cycles as operating time / typical		10,000,000
Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required		gL/gG: 6 A, or quick: 10 A
Resistance to direct current / of the cable / maximum	Ω	30
Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum	m	1,000
Make time / with automatic start		
• for DC / maximum	ms	80
Backslide delay time / at mains power cut		
• maximum	ms	100
Adjustable backslide delay time		
after opening of the safety circuits	s	0.5 30

Recovery time / after mains power cut / typical	S	1
Pulse duration		
of the sensor input / minimum	ms	25
of the ON pushbutton input / minimum	s	0.025

Control circuit:		
Type of voltage / of the controlled supply voltage		DC
Control supply voltage / 1 / for DC / rated value	V	24
operating range factor control supply voltage rated value / of the magnet coil		
• at 50 Hz		
• for AC		0.85 1.1
• at 60 Hz		
• for AC		0.85 1.1
• for DC		0.85 1.1

Installation/mounting/dimensions:		
mounting position		any
Type of mounting		screw and snap-on mounting
Width	mm	45
Height	mm	138.5
Depth	mm	120

Connections:	
Design of the electrical connection	spring-loaded terminals
Type of the connectable conductor cross-section	
• solid	2x (0.25 1.5 mm²)
finely stranded	
with wire end processing	2 x (0.25 1.5 mm²)
without wire end processing	2x (0.25 1.5 mm²)
Type of the connectable conductor cross-section / for AWG conductors	
• solid	2x (24 16)
• stranded	2x (24 16)

Product Function:		
Product function		
light barrier monitoring	No	
standstill monitoring	No	
protective door monitoring	Yes	
automatic start	Yes	

<ul> <li>magnetic switch monitoring Normally closed contact-Normally open contact</li> </ul>	No
rotation speed monitoring	No
laser scanner monitoring	No
monitored start-up	No
light grid monitoring	No
<ul> <li>magnetic switch monitoring Normally closed contact-Normally closed contact</li> </ul>	No
emergency stop function	No
step mat monitoring	Yes
Suitability for interaction / pressing control	No
Acceptability for application	
<ul> <li>monitoring of floating sensors</li> </ul>	Yes
<ul> <li>monitoring of non-floating sensors</li> </ul>	No
safety cut-out switch	Yes
position switch monitoring	Yes
EMERGENCY-OFF circuit monitoring	No
valve monitoring	No
tactile sensor monitoring	No
magnetically operated switches monitoring	No
safety-related circuits	Yes
<b>,</b>	

## Certificates/approvals:

Verification of suitability	BG, SUVA, UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508
• TÜV (German technical inspectorate) certificate	Yes
UL-registration	Yes
BG BIA certificate	Yes

#### General Product Approval











**Test Certificates** 



**EMC** 

other

Functional Safety / Safety of Machinery

Declaration of Conformity

Special Test
Certificate

Confirmation

Environmental Confirmations





CE EG-Konf.

## Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

#### Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

#### Cax online generator:


http://www.siemens.com/cax

#### Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3TK2828-2BB40/all

## Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3TK2828-2BB40



last change: Feb 18, 2013