## **SIEMENS**

Product data sheet 5TE1340

DISCONNECTOR, 92MM 200A 3POLE TRANSPARENT



Similar to image

Technical data:		
Number of poles		3
Design of the operating mechanism		selector switch
Product equipment / interlock		No
Continuous current / rated value	Α	200
Acceptability for application / emergency stop switch		No
Type from device		other
Design of the electrical connection / for main current circuit		screw-type terminals
Number of NC contacts / for auxiliary contacts		0
Acceptability for application / safety cut-out switch		No
Type of the driving mechanism / motor drive		No
Number of NO contacts / for auxiliary contacts		3
Number of change-over switches / for auxiliary contacts		0
Operating voltage / at 50/60 Hz / for AC / rated value	V	690
Service power / at AC 23 A / at 400 V / at 50/60 Hz / rated value	kW	88
Protection class IP		IP20
Acceptability for application / main switch		No
Acceptability for application / switch disconnector		Yes
Product extension / optional / motor drive		No

Product extension / optional / voltage trigger	No
Type of fixing / 4-hole front mounting	No
Type of fixing / central front mounting	No
Suitability for integration / distribution board	Yes
Acceptability for application / maintenance/repair switch	Yes

## Certificates/approvals:

**General Product Approval** 

**Declaration of** Conformity

other









Environmental Confirmations

## **Further information:**

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/lowvoltage/mall

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/5TE1340/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=5TE1340

**CAx-Online-Generator** 

http://www.siemens.com/cax

## **Tender specifications**

Datanorm GAEB81 GAEB83 RTF TXT



last change: Nov 5, 2012